

ENCLOSE CARPORT TO LIVABLE AT THE _____ RESIDENCE

APPLICABLE CODES

ALL CONSTRUCTION SHALL COMPLY WITH THE
FOLLOWING CODES AND AMENDMENTS:
2006 IRC INTERNATIONAL RESIDENTIAL CODE
CITY OF MESA AMENDMENTS

DRYER SHALL NOT VENT INTO ROOM

IDENTIFY ALL GAS APPLIANCES IN
UTILITY, LAUNDRY AND STORAGE
ROOMS, SHOW LOCATIONS AND SIZES
OF ALL COMBUSTION AIR VENTS

OUTLETS

ATTIC ACCESS TO REMAIN

EXISTING POSTS AND BEAMS
TO REMAIN IN PLACE

ADD ROOM NAMES OF ADJACENT ROOMS

ALL EXTERIOR DOORS AND WINDOWS
SHALL COMPLY WITH CITY'S SECURITY
ORDINANCE NO. 2225

HOW IS ROOM HEATED AND COOLED?


FLOOR PLAN


PUT DIMENSIONS AT THE CIRCLES



PROPERTY ADDRESS=

CITY OF MESA – FOR REFERENCE ONLY – EXAMPLE






ENCLOSURE

PUT DIMENSIONS AT THE CIRCLES

ALL METAL CONNECTORS SHALL BE
ICC LISTED AND INSTALLED PER
MANUFACTURER'S INSTRUCTIONS

PROPERTY ADDRESS=

CITY OF MESA – FOR REFERENCE ONLY – EXAMPLE



SHOW ELECTRICAL SERVICE AND WIRES

SHOW GAS OR PROPANE

SHOW WATER METER

PUT DIMENSIONS AT THE CIRCLES

HATCH THE PROPOSED CONSTRUCTION

SITE PLAN

PROPERTY ADDRESS=

CITY OF MESA – FOR REFERENCE ONLY – EXAMPLE